



**RFB-20-20
ADDENDUM 1
CLOSED METAL SHELVING for Evidence Storage**


DATE: August 20, 2020
FROM: Jennifer Nellis, Purchasing Agent
BID DUE DATE: September 1, 2020, BY 4:00 P.M. OUR CLOCK

The following information is being provided to all prospective bidders and is hereby made a part of the above-referenced bid documents. **Bidders must acknowledge this Addendum 1 with their bid.** This addendum is a total of two (2) page(s) and includes the attendee list from the mandatory site visit.

CLARIFICATION, ADDITIONAL INFORMATION AND CHANGES:

1. **Are hinged doors acceptable on the fixed carriage?**
Hinged doors are appropriate.
2. **Does the City require decking in-between the floor rails, such as a filler piece or ramp to minimize tripping hazards?**
Yes, decking of some sort is required in-between the floor rails, to mirror the system as installed in the upper NE corner of the building.
3. **Is plywood needed below the stationary shelving?**
The City prefers for the level of the bottom shelves of all units to be at the same height. Therefore, it may be necessary to install plywood underneath the stationary shelving.
4. **Is reinforcement in terms of a shelf support required?**
No, a shelf support is not required as long as the shelf is otherwise designed to handle 200 pounds.
5. **Does the City require solid vertical panels between the sections of shelving?**
This question is being discussed by staff and will be answered in a subsequent addenda.
6. **Can either or both the wall-mounted air conditioning unit and the hanging fan be relocated to make better use of installed shelving?**
This question is being discussed by staff and will be answered in a subsequent addenda.
7. **Will the floor handle the intended load if shelving is added, and is full to capacity?**
The Police Evidence Technicians are not engineers, which is why an architect designed the new floor specifications and construction details with full knowledge of the intended use of the space.
8. **Given constraints of the equipment installed in the space, will the City accept a 33 inch aisle between shelves?**
Yes, a 33 inch aisle is acceptable to the City.
9. **Does the City intend for the stationary shelves to have an open back, and also locking doors?**
The City currently has both open-back and closed-back cabinets installed. Open-back installation will be allowed, but is not required. Doors must lock with a key.

Visit the city website for bid documents, addendum, and project updates www.ci.wheatridge.co.us
POINT OF CONTACT: Jennifer Nellis, Purchasing Agent, jnellis@ci.wheatridge.co.us, or phone 303-235-2811. Do not contact the requesting department.




MANDATORY SITE-VISIT SIGN-IN SHEET

**RFB-20-20 Closed Metal Shelving System for Evidence Storage
WEDNESDAY, AUGUST 19, 2020, AT 2:00 P.M. LOCAL TIME**

City representatives:

Jennifer Nellis and Sandie Carter

ATTENDEES:

Interior Concepts

Jeff Singer
 Senior Account Manager
 (P) 303.377.2336 | (F) 303.377.2696 | (C) 303.919.8936
 4601 Quebec Street | Suite C10 | Denver, CO 80216
 jeff@interiorconceptsdenver.com

Bill Schuster, CRM
 President
Specializing in High-Density Storage Equipment, Shelving, Cabinets and Lockers
CERTIFIED BUSINESS SERVICES, INC.
 Phone: (303) 692-8700
 Cell: (303) 995-1775
 Toll Free: (877) 825-8782
 Fax: (303) 692-8744
 E-mail: bill@filingworld.com
 6920 South Jordan Road
 Suite K
 Centennial, CO 80112
 www.filingworld.com

H & M
 DISTRIBUTING
Commercial Shelving and Locker Systems
STEVE PETERSEN
 303.298.8181 P 800.779.3278 T
 303.475.9869 C 303.298.0736 F
 steve@hmdistributing.com

Account Manager
PAM WAGNER
 OFFICE 720-570-5438
 MOBILE 720-275-1394
 pwagner@eonoffice.com
 60 TEJON STREET DENVER, CO 80223

STACEY O'DONNELL
 Account Manager
 direct 303.576.7211
 cell 303.868.0062
 main 303.574.1115
 sodonnell@officescapes.com
 www.officescapes.com
 SHOWROOM + MAIN OFFICE 9900 East 51st Avenue Denver, Colorado 80238
 STUDIO 1445 Market Street Denver, Colorado 80202

Shelf Image, Inc.
 Authorized Montel Distributor
Marshall Davis
 Sales Manager
 Cell 303-669-5515 Toll Free 800-258-3965
 4200 Jackson St. #24 Denver, CO 80216
 marshall@shelfimage.net www.shelfimage.net

Hertz Furniture
 Experts by Design
Heather Gropp
 Regional Sales Manager
 Colorado
 O: 800-526-4677 x 1271
 C: 720-481-7101
 heather@hertzfurniture.com
 50 YEARS 305 Inverness Way South, Englewood, CO 80112
 www.hertzfurniture.com

MOTUS
 SPACE SOLUTIONS
SAM AUSLOOS
 SALES MANAGER
 sausloos@motusspacesolutions.com
 608.213.7140 | 844.947.4250
 motusspacesolutions.com
 BUD SWARTZ